

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 09/08/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0010
6. ISSUED BY CODE		raa	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO.
			x	N40085-10-R-0010
				9B. DATED (SEE ITEM 11) 09/01/10
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

10-0010, Renovate FC-574 BEQ

SEE CONTINUATION SHEET

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Section 23 05 93, paragraph 3.3.3, change DALT requirement of not more than 20%, to 100% of (all) duct shall have duct air leakage test performed.

2. **Question:** Drawing E-502 Lighting Fixture Schedule shows a Type F Fixture. I am unable to locate a Type F fixture, is this a misprint?

Answer: No, Type F is to be used in the sleeping rooms as the fixture above the mirror. Type F fixtures were mislabeled as a Type G fixture on sheet E-402.

3. **Question:** Line Item 0002 on the Bid Form includes the replacement of the telecommunications system. Where is the new telecommunications backboard to be located?

Answer: The contractor shall coordinate preferred location of communications backboard with Steve Daigle at the Base Telephone office; the contact information is provided on the drawings. Cable and terminations need to be at the work area outlet faceplate to the patch panel in the new comm. room location, not to the back board. Conduit is from the work area outlet to the back board. If there is no existing room for new terminations and cable in the comm. room additional patch panels, racks, and cable management need to be installed. All should be per MCB Camp Lejeune Telephone Specifications Section 27 10 00.

4. **Question:** The Telecommunications backboard detail on drawing E-603 shows 3" conduits to an additional comm. room. This is an example but is more than one communications room required in the building?

Answer: There is no additional comm. room in the building for base managed communications. The Telecommunications Backboard Example is provided as reference of the Camp LeJeune standard backboard requirements.

5. **Question:** The Telecommunications backboard detail and voice/data riser on drawing E-603 say to install 4" conduit with pull string to telephone entrance riser point. These conduits are shown below grade. Are we required to remove the floor in order to install these conduits or can they be run above grade until they exit the building? Where is the telephone entrance riser point?

Answer: Conduits can be run above grade to entrance point located in mechanical room #1 on the first floor.

N40085-10-R-0010

Amendment 0002

Page 3 of 3

6. **Question:** Drawing E-402 New Work Note #9 says "Install new circuit for Fixture G. One switch to control uplight; second switch to control downlight." It appears the Type G Fixture is only a downlight fixture. Is the additional circuit still required?

Answer: Type G fixture above the mirror in sleeping rooms is to be Type F. New Work Keynote #9 addresses requirement for separate controls for up and downlight for Type F fixture.